



SALES SPECIFICATION SHEET  
**DSR C 8X30**  
Granular Activated Carbon

Test	Specification		Calgon Carbon Test Method
	Min	Max	
IODINE NUMBER, mg/g	800	-	TM-4,ASTM D4607
MOISTURE (AS PACKAGED), wt%	-	2	TM-1,ASTM D2867
DENSITY (APPARENT), g/cc	-	0.60	TM-7,ASTM D2854
< 30 US MESH [0.600 mm] (PAN), wt%	-	5	TM-8,ASTM D2862

**Typical Properties:**

DSR C 8X30 is not to be used for Food Grade or Potable Water applications.

**Calgon Carbon Corporation's activated carbon products are continuously being improved and changes may have taken place since this publication went to press. (12830-06/15/2016)**



**Geofluid Processors Private Limited**

112, Building No.2, Mittal Industrial Estate,  
Andheri Kurla Road, Marol, Andheri (E), Mumbai - 400 059.

+91-22- 6155 5888  
info@geofluid.com

+91-22-6155 5800  
www.geofluid.com