



# CARBSORB 816 PSC

Granular Activated Carbon

Test	Specification		Calgon Carbon Test Method
	Min	Max	
DENSITY (APPARENT), g/cc	0.25	-	TM-7,ASTM D2854
IODINE NUMBER, mg/g	900	-	TM-4,ASTM D4607
ABRASION NUMBER	70	-	AWWA B604
MOISTURE (AS PACKAGED), wt%	-	3	TM-1,ASTM D2867
pH (EXTRACTABLE)	7	-	TM-15
UNIFORMITY COEFFICIENT	-	2.1	TM-47,ASTM D2862
WATER SOLUBLE ASH, wt%	-	0.5	TM-16
8 US MESH [2.36 mm], wt%	-	5.0	
< 16 US MESH [1.18 mm] (PAN), wt%	-	5.0	

**Typical Properties:**

THIS PRODUCT IS NOT INCLUDED IN THE SCOPE OF CCC'S QUALITY SYSTEM CERTIFIED TO ISO 9001.  
NOTE: CCC'S Quality System elements are applied whenever possible.

**Calgon Carbon Corporation's activated carbon products are continuously being improved and changes may have taken place since this publication went to press. (15571-09/11/2017)**

**Geofluid Processors Private Limited**

112, Building No.2, Mittal Industrial Estate,  
Andheri Kurla Road, Marol, Andheri (E), Mumbai - 400 059.

+91-22- 6155 5888

info@geofluid.com

+91-22-6155 5800

www.geofluid.com